

CITY OF DONCASTER COUNCIL
HOLIDAY CARAVAN SITE MODEL STANDARDS 1989

Schedule of Conditions

Note - A static holiday caravan shall not be occupied by the same person or persons for more than twenty-eight days within thirty-six consecutive days.

Site Boundaries

1. The boundaries of the site should be clearly marked, for example by fences or hedges. In addition, the site owner should give the Local Authority a plan of its layout. It is recommended that a three metre wide area should be kept clear within the inside of all boundaries.

Density and Space between Caravans

2. Subject to the following variations, the minimum spacing distance between static caravans made of aluminium or other materials within similar fire performance properties should be not less than 5 metres between units, 3.5 metres at the corners. For those with a plywood or similar skin or where there is a mixture of holiday caravans of aluminium and plywood, the separation distance should be 6 metres. The point of measurement for porches, awnings, etc is the exterior cladding of the caravan.
 - Porches may protrude 1 metre into the 5 metres and should be of the open type.
 - Where awnings are used, the distance between any part of the awning and an adjacent caravan should not be less than 3 metres. They should not be of the type which incorporates sleeping accommodation and they should not face each other or touch.
 - Eaves, drainpipes and bay windows may extend into the 5 metre space provided the total distance between the extremities of two adjacent units is not less than 4.5 metres.
 - Where there are ramps for the disabled verandas and stairs extending from the unit, there should be 3.5m clear space between them (4.5 metres if mixture of caravans) and such items should not face each other in any space. If they are enclosed, they may need to be considered as part of the unit and, as such, should not intrude into the 5 metre (or 6 metre) space.
 - A shed or a covered storage space should be permitted between units only if it is of non-combustible construction (including non-combustible roof) and sufficient space is maintained around each unit so as not to prejudice means of escape in case of fire. Windows in such structures should not face towards the unit on either side. Covered walkways should in no circumstances be allowed within the 5 or 6 metre space. For cars and boats between units, see Standard (22).

NB - Please note that the implementation of any of the above matters may require planning permission. You are therefore advised to discuss any plans/intentions with the Planning Department before commencement.

Roads, Gateways and Footpaths

3. Roads and footpaths should be designed to provide adequate access for fire appliances. (Detailed guidance on turning circles etc is available from fire authorities). Roads of suitable material should be provided so that no static caravan standing is more than 50 metres from a road. Where the approach to the caravan is across ground that may become difficult or dangerous to negotiate in wet weather, each standing should be connected to a carriageway by a footpath with a hard surface. Roads should not be less than 3.7 metres wide, or, if they form part of a clearly marked one way traffic system, 3 metres wide. Gateways should be a minimum of 3.1 metres wide and have a minimum height clearance of 3.7 metres. Footpaths should not be less than 0.75 metres wide. Roads should have no overhead cable less than 4.5 metres above the ground. They should be suitably lit taking into account the needs and characteristics of a particular site. Emergency vehicle routes within the site should be kept clear of obstruction at all times.

NB - Please note that the implementation of any of the above matters may require planning permission. You are therefore advised to discuss any plans/intentions with the Planning Department before commencement.

Hard Standings

4. Where possible, every static caravan should stand on a hard standing of suitable material, which should extend over the whole area occupied by the caravan placed upon it, and should project a sufficient distance outwards from the entrance or entrances of the caravan to enable occupants to enter and leave safely.

Hard standings may be dispensed with if the caravans are removed during the winter, or if they are situated on a ground which is firm and safe in poor weather conditions.

Fire Precautions

5. Site operators must comply with their legal duties under The Regulatory Reform (Fire Safety) Order 2005. As a licenced site you must undertake a fire risk assessment and implement the required controls.

Maintenance

6. All alarm and fire fighting equipment should be installed, tested and maintained in working order by a competent person and be available for inspection by, or on behalf of, the licensing authority. A log-book should be kept to record all tests and any remedial action.
7. All equipment susceptible to damage by frost should be suitably protected.

Fire Notices

8. A clearly written and conspicuous notice should be provided and maintained at each fire point to indicate the action to be taken in case of fire and the location of the nearest telephone. This notice should include the following:

“On discovering a fire:

- i) Ensure the caravan or site building involved is evacuated.
- ii) Raise the alarm.

iii) Call the fire brigade (the nearest telephone is sited ...).

iv) Attack the fire using the fire fighting equipment provided, if safe to do so.

It is in the interest of all occupiers of this site to be familiar with the above routine and the method of operating the fire alarm and fire fighting equipment."

Telephones

9. An immediately accessible telephone should be available on the site for calling the emergency services. A notice by the telephone should include the address of the site.

Storage of Liquefied Petroleum Gas (LPG)

10. The storage of LPG should comply with LPGA Code of Practice 7: "Storage of full and empty LPG cylinders and cartridges" or LPGA Code of Practice 1 Part 1: "Bulk storage at fixed installations: installation and operation of vessels located above ground", as appropriate.

Exposed gas bottles or cylinders should not be within the separation boundary of an adjoining unit.

LPG installations should conform to British Standard 5482, "Code of Practice for Domestic Butane and Propane Gas Burning Installations, Part 2: 1977 Installations in Caravans and Non-Permanent Dwellings".

Electrical Installations

11. Sites should be provided with an electricity supply sufficient in all respects to meet all reasonable demands of the caravans situated on them.
12. Such electrical installations, other than Electricity Board works and circuits subject to regulations made by the Secretary of State under Section 16 of the Energy Act 1983 and Section 64 of the Electricity Act 1947, should be installed, tested and maintained in accordance with the provisions of the Institution of Electrical Engineers' (IEE) Regulations for Electrical Installations for the time being in force, and where applicable, to the standard which would be acceptable for the purposes of the Electricity (Overhead Lines) Regulations 1988, Statutory Instrument 1988 No 1057.
13. Work on electrical installations and appliances should be carried out only by competent persons such as the manufacturer's appointed agent, the electricity supplier, a professionally qualified electrical engineer, a member of the Electrical Contractors' Association, a contractor approved by the National Inspection Council for Electrical Installation Contracting, or a qualified person acting on behalf of one of the above. The installations should be inspected periodically: under IEE Wiring Regulations, every year or such longer period (not exceeding three years) as is considered appropriate in each case. When an installation is inspected, it should be judged against the current regulations.

The inspector should, within one month of such an inspection, issue an inspection certificate in the form prescribed in the IEE Wiring Regulations which should be retained by the site operator and displayed, supplemented or replaced by subsequent certificates, with the site licence. The cost of the inspection and report should be met by the site operator or licence holder.

14. If an inspection reveals that an installation no longer complies with the regulations extant at the time it was first installed, any deficiencies should be rectified. Any major alterations and extensions to an installation affected by them should comply with the latest version of the IEE Wiring Regulations.
15. If there are overhead electric lines on the site, suitable warning notices should be displayed at the entrance to the site on supports for the line. Where appropriate, particular attention should be drawn to the danger of masts of yachts or dinghies contacting the line.

Water Supply

16. All sites should be provided with a water supply in accordance with appropriate Water Bye-laws and statutory quality standards.

Drainage, Sanitation and Washing Facilities

17. Satisfactory provision should be made for foul drainage, either by connection to a public sewage treatment works or by discharge to a properly constructed septic tank or cesspool approved by the Local Authority.
18. Properly designed disposal points for the contents of chemical closets should be provided, with an adequate supply of water for cleaning the containers.
19. For caravans without their own water supply and water closets, communal toilet blocks should be provided, with adequate supplies of water, on at least the following scales:

Men: 1 WC and 1 urinal per 15 caravans

Women: 2 WCs per 15 caravans

1 wash basin for each WC or group or group of WCs

1 shower or bath (with hot and cold water) for each sex per twenty caravans

Toilet blocks should be sited conveniently so that all site occupants may have reasonable access to one by means of a road or footpath.

Refuse Disposal

20. Every caravan standing should have an adequate number of suitable non-combustible refuse bins with close-fitting lids or plastic bags. Arrangements should be made for the bins to be emptied regularly.
21. Where communal refuse bins are also provided these should be of similar construction and housed within a properly constructed bin store.

Parking

22. One car only may be parked between adjoining caravans provided that the door to the caravan is not obstructed. Suitably surfaced parking spaces should be provided where necessary to meet the additional requirements of the occupants and their visitors. Plastic or wooden boats should not be parked between units.

NB - Please note that the implementation of any of the above matters may require planning permission. You are therefore advised to discuss any plans/intentions with the Planning Department before commencement.

Recreation Space

23. Where children stay on the site, space equivalent to about one-tenth of the total area should be allocated for children's games and/or other recreational purposes. This provision will normally be necessary because of the limited space available round the caravans, but may be omitted where there are suitable alternative publicly provided recreational facilities which are readily accessible.

Notices

24. A suitable sign should be prominently displayed at the site entrance indicating the name of the site.
25. A copy of the site licence with its conditions should be displayed prominently on the site.
26. Notices and a plan should be displayed on the site setting out the action to be taken in the event of an emergency. They should show where the police, fire brigade, ambulance and local doctors can be contacted, and the location of the nearest public telephone. The notices should also give the name and location/telephone number of the site licence holder or his/her accredited representative. At sites subject to flood risk, warning notices should be displayed giving advice about the operation of the flood warning system.
27. All notices should be suitably protected from the weather and displayed where possible out of the direct rays of the sun, preferably in areas lit by artificial lighting.