



Contact: Ellen Dook

Ref: [REDACTED]

Email: FOIrequests@doncaster.gov.uk

Date: 25th June 2024

Dear [REDACTED]

Re: Request for information under the Freedom of Information Act 2000

Thank you for your Freedom of Information request dated 14 June 2024 for information about road works inspections. Please find below City of Doncaster Council's responses to the questions you have raised.

Request

Jossey Lane and Sprotbrough Road road works inspection reports.

Response

Please find this information enclosed.

I hope that this information is useful to you.

The City of Doncaster Council estimates that it has cost £49 to respond to this request for information.

Reviewing any decisions made

If you are not happy with this reply you can ask us to review our response. To do this write to us within 40 working days of receiving your response at the address below or email FOIAppeals@doncaster.gov.uk

If you do not agree with the review decision you can apply to the Information Commissioner's Office (ICO) for a decision about our compliance or otherwise with the Freedom of Information legislation. Contact details for the ICO are: Information Commissioner's Office, Wycliffe House, Water Lane, Wilmslow, Cheshire, SK9 5AF. www.ico.org.uk Telephone 0303 123 1113.

Yours sincerley,

Ellen Dook
Information Governance Officer

Reference: QA802I511948A-INSP-01

Status: Recorded

Works location:
SPROTBROUGH ROAD, DONCASTER, SPROTBROUGH

Inspection details

Inspection type

Live site

Inspection category

Category A

Inspection date

18/04/2024

Inspection start time

11:18

Inspection outcome

Inspection outcome

Passed

Additional information

Additional comments

Works in progress, no gang on site, awaiting backfill and reinstatement.

Related information

Works promoter

NORTHERN POWERGRID (YORKSHIRE) PLC

Highway authority

DONCASTER METROPOLITAN BOROUGH COUNCIL

Reference: QB091279355390210-INSP-01

Status: Recorded

Works location:

JOSSEY LANE, DONCASTER, SCAWTHORPE

Inspection details

Inspection type

Live site

Inspection category

Category A

Inspection date

19/04/2024

Inspection start time

09:30

Inspection outcome

Inspection outcome

Failed - low

Non compliance areas

Non compliance area

Signing Lighting & Guarding - Pedestrian provision

Details: SITE 1 - Kerb ramp not rigidly secured to the f/way surface. 4h SLG defect.

Additional information

Additional comments

Works in progress, 2-way signals, Kerb ramp not rigidly secured to the f/way surface. 4h SLG defect. Kerb ramp not rigidly secured to the f/way surface. 4h SLG defect. Take immediate action to remedy a lower risk signing, lighting, and guarding inadequacy and notify the Authority within 4 hours that you have completed the works.

Related information

Works promoter

YORKSHIRE WATER

Highway authority

DONCASTER METROPOLITAN BOROUGH COUNCIL